

RETAIL TRADE



MOST CITED STANDARDS IN THE RETAIL INDUSTRY JANUARY 1, 2003 TO DECEMBER 31, 2003

RANK		STANDARDS CITED	NUMBER
1	1910.38	This section applies to emergency-action and fire-prevention plans required by particular HIOSH standards.	10
2	1910.178	This section contains safety requirements relating to fork trucks, tractors, platform lift trucks, and motorized hand trucks.	9
3	1910.22	Places of employment , passageways, and storerooms were not kept clean and orderly and in a sanitary condition.	8
3	1910.304	This section contains grounding and overcurrent protection requirements for systems, circuits, and equipment.	8
3	1910.305(g)	Flexible cords were used as a substitute for fixed wiring where not permitted. Flexible cords were not connected to devices and fittings so that strain relief was provided, which would have prevented pull from being transmitted to joints.	8
4	1910.303	Electrical equipment was not free from recognized hazards that were likely to cause death or serious physical harm to employees.	7

RANK	STANDARDS CITED	NUMBER
4	1910.305(b) Conductors entering boxes, cabinets, or fittings were not protected from abrasion, and openings through which conductors entered were not effectively closed . All pull boxes, junction boxes, and fittings were not provided with covers approved for the purpose.	7
5	1910.37 Exits were not marked by a readily visible sign and were not readily accessible at all times.	5
5	1910.176(b) The storage of material created a hazard.	5
6	60-2 Safe workplaces and practices were not provided. Standards for an Occupational Safety and Health Program were not met.	4
6	1910.132 Personal safety equipment or clothing was not worn by employees who were exposed to hazards where these devices were expected to prevent injury.	4